



Alexandria Health Department



Stephen A. Haering, MD, MPH
Health Director

REPLY TO:
Environmental Health Division
4480 King Street, Suite 360
Alexandria, VA 22302
Phone: (703) 746-4910
Fax: (703) 746-4919
alexandriava.gov/AquaticHealth

2011 Preoperational Checklist

Filter Room

- "Authorized personnel only" placard posted on filter room door?
- Filter room is secured by a lock?
- Swimming Facility Information placard posted in pump room?
- Chemical Safety Placard visibly posted in pump room?
- Filter system operations placard visibly posted in pump room (how to filter, backwash, vacuum, etc.)
- Filter system properly color coded, with arrows indicating direction of flow?
- Properly sized flow meter?
- Influent, and effluent gauges are readable and working?
- Chemical feeder is properly sized and working?
- Thermometer in effluent line of heater for spa or heated pool?
- Extra hair and lint strainer basket for each motor?
- Goggles, apron, and gloves provided?
- Filter room light fixtures working?
- Floors, walls, ceiling and light fixtures in good repair?
- Air gap provided for backwash pipe?
- MSDS sheets provided for all pool chemicals onsite?
- Secondary containment vat for pool chemicals and lids for chemical vats?
- Documentation that SVRS system has been tested?

Rest Rooms / Locker Rooms

- All showers, sinks, urinals and toilets working?
- Shower temperature is not lower than 90F and does not exceed 110F?
- Floors, walls, ceiling, and light fixtures in good repair?
- Soap provided for sinks and showers?
- Paper towels and toilet paper provided?

Spa

- Spa Rules Placard posted at spa?
- Clock provided that is easily visible from inside the spa?
- Thermometer provided in the spa?
- Main drains secure?
- Skimmer basket, weir and skimmer lid provided and in good condition?
- If used at night, do lights work (in-pool and area lights)?
- Railing secure and in good condition?
- Depth markings provided along the tile line and deck?

KING STREET
4480 King Street
Alexandria, VA 22302
(703) 746-4996

CASEY HEALTH CENTER
1200 N. Howard Street
Alexandria, VA 22304
(703) 746-4886

TEEN WELLNESS CENTER
3330 King Street
Alexandria, VA 22302
(703) 746-4776

ARLANDRIA (WIC)
3802 Executive Ave. #D-2
Alexandria, VA 22305
(703) 519-1957

Main Pool

- Pool rules posted?
- Lifeline and floats provided at 5-foot transition line in pool?
- Skimmer basket, weir and lid provided for each skimmer and in good condition?
- Depth markings provided along the tile line and on the deck?
- If used at night, do lights work (in-pool and area lights)?
- Ladders and railing secure and in good condition?
- Lifeguard stands in good condition?
- Main drains secure?
- Water Quality Placard provided and visibly posted?
- Bather load placard posted at front entrance?
- No diving signs?
- Thermometer provided in skimmer if pool is heated?
- Transition tile at leading edge of steps and 5-ft transition line present and in good condition?

Wading Pool

- Self-closing gate?
- Main drains secure?
- White coat and deck in good repair?
- Wading pool separated from pool area with fence?

Safety Equipment

- Backboard provided with straps, head assembly, and two emergency blankets?
- Rescue tube(s) provided?
- Shepherds hook provided and attached to pole?
- Emergency telephone working and properly located?
- First Aid Kit?
- Bloodborne pathogen kit?

General

- Acceptable backflow prevention devices provided for all hose bibs within the pool area and filter room?
- Deck and coping stones in good condition?
- White coat in good condition?
- Adequate chemical test kit provided?
- Cyanuric Acid test kit provided onsite if CYA is used?
- Emergency gate accessible? Key for emergency gate available onsite?
- Pool fence in good repair?
- Chemical records / log book?
- Water contamination placard posted at entrance or with pool rules (11-11-66 A)?
- Instructions for addressing fecal contamination provided onsite?

Administrative

- All items from 2010 deficiency letter addressed?
- Electrical Inspection Form completed and submitted?
- Permit Application completed and submitted?
- Permit fee paid?

* This list is intended to be a *general* guide. It is not a substitute for a thorough understanding of the pool regulations.